



SECTION ELEVATION

NOTE: PVC DR 18, C-900 PIPE SHALL BE REQUIRED WHEN THE BOTTOM OF THE STORM SEWER IS WITHIN 18" OF THE TOP OF THE SANITARY SEWER. UNDER NO CIRCUMSTANCES SHALL THE STORM SEWER BE SUPPORTED BY THE SANITARY LINE



REFERENCE STANDARD SPECIFICATIONS FOR WATER AND SEWER MAIN CONSTRUCTION IN ILLINOIS (FIFTH EDITION)

**YORKVILLE-BRISTOL
SANITARY DISTRICT**

SANITARY SEWER AT
STORM SEWER CROSSING

DESIGNED	JWF	APPROVED	PFM	SCALE	NTS
DRAWN		DATE	10/9/06		STD-009